

# Glass and Glazing Federation

Certifies that

*Garware Polyester Ltd*


Certificate No: *TC 0132*

Garware 300 Micron 3 Ply Clear Safety Film on 6mm Float Glass  
passed Class 1B  
of BS EN 12600 'Glass in Building – Pendulum  
Test – Impact Test Method and Classification  
for Flat Glass'

Tested at Wintech Engineering Ltd, UKAS accredited Test Laboratory, No.2223


Issued: *15/12/2002*

Chief Executive:



N Rees

Testing Officer:



S H Rice



Glass and Glazing Federation

Glass and Glazing Federation  
44 – 48 Borough High Street  
London  
SE1 1XB  
Tel: 020 7207 5872  
Fax: 020 7357 7458

Test Facility:  
WINTech Engineering Ltd  
Halesfield 2  
Telford TF7 4QH  
Tel: 01952 586580  
Fax: 01952 586585