

# Glass and Glazing Federation

Certifies that

*Garware Polyester Ltd*


Certificate No: *TC 0198*

Garware 100 Micron Clear Safety Film on 6.8mm Laminated Glass  
passed Class P1A (Drop height 1.5metre)  
of BS EN 356:2000 'Glass in Building – Security Glazing-Testing  
and Classification of resistance against manual attack'

Tested at Wintech Engineering Ltd, UKAS accredited Test Laboratory, No.2223


Issued: *29/03/2004*

Chief Executive:



N Rees

Testing Officer:



S H Rice

Test Facility:

WINTech Engineering Ltd  
Halesfield 2  
Telford TF7 4QH  
Tel: 01952 586580  
Fax: 01952 586585



Glass and Glazing Federation

Glass and Glazing Federation  
44 – 48 Borough High Street  
London  
SE1 1XB  
Tel: 020 7207 5872  
Fax: 020 7357 7458