

Glass and Glazing Federation

Certifies that

Garware Polyester Limited

Certificate No: *TC 0231*

Garware 100 Micron Exterior Safety Film has Passed
Class B of BS 6206 1981 'Impact Performance Requirements
for Flat Safety Glass and Safety Plastics for Use in
Buildings' on 6mm Clear Float Glass

Tested at Wintech Engineering Ltd, UKAS accredited Test Laboratory, No.2223


Issued: *29 March 2004*

Chief Executive:



N Rees

Testing Officer:



S H Rice

Test Facility:
WINTech Engineering Ltd
Halesfield 2
Telford TF7 4QH
Tel: 01952 586580
Fax: 01952 586585



Glass and Glazing Federation

Glass and Glazing Federation
44 - 48 Borough High Street
London
SE1 1XB
Tel: 020 7207 5872
Fax: 020 7357 7458