

Glass and Glazing Federation

Certifies that

Garware Polyester Ltd

Certificate No: **TC 0201**

Garware 175 Micron Clear Safety Film on 6mm Clear Float Glass
Passed Class P1A (Drop height 1.5 metre)
of BS EN 356:2000 'Glass in Building – Security Glazing-Testing
and Classification of resistance against manual attack'


Tested at Wintech Engineering Ltd, UKAS accredited Test Laboratory, No.2223

Issued: **29/03/2004**

Chief Executive:



N Rees
Testing Officer:



S H Rice

Test Facility:
WINTECH Engineering Ltd
Halesfield 2
Telford TF7 4QH
Tel: 01952 586580
Fax: 01952 586585



Glass and Glazing Federation

Glass and Glazing Federation
44 – 48 Borough High Street
London
SE1 1XB
Tel: 020 7207 5872
Fax: 020 7357 7458