

# Glass and Glazing Federation

Certifies that

*Garware Polyester Ltd*

Certificate No: **TC 0139**

Garware 175 Micron 2 PlyClear Safety Film on 6mm Float Glass  
passed Class A  
of ANSI Z97.1 American National Standard for Safety Glazing  
Materials used in Building-Safety Performance Specification and  
Methods of Test

Tested at Wintech Engineering Ltd, UKAS accredited Test Laboratory, No.2223


Issued: **16/12/2002**

Chief Executive:



N Rees

Testing Officer:



S H Rice



Glass and Glazing Federation

Glass and Glazing Federation  
44 - 48 Borough High Street  
London  
SE1 1XB  
Tel: 020 7207 5872  
Fax: 020 7357 7458

Test Facility:  
WINTech Engineering Ltd  
Halesfield 2  
Telford TF7 4QH  
Tel: 01952 586580  
Fax: 01952 586585