

Glass and Glazing Federation

Certifies that

Garware Polyester Ltd

Certificate No: *TC 0204*

Garware 200 Micron Clear Safety Film on 6.8mm Clear Laminated
Float Glass

Passed Class P2A (Drop height 3 metre)
of BS EN 356:2000 'Glass in Building – Security Glazing-Testing
and Classification of resistance against manual attack'

Tested at Wintech Engineering Ltd, UKAS accredited Test Laboratory, No.2223


Issued: *29/03/2004*

Chief Executive:



N Rees

Testing Officer:



S H Rice



Glass and Glazing Federation

Glass and Glazing Federation
44 – 48 Borough High Street
London
SE1 1XB
Tel: 020 7207 5872
Fax: 020 7357 7458

Test Facility:
WİNTECH Engineering Ltd
Halesfield 2
Telford TF7 4QH
Tel: 01952 586580
Fax: 01952 586585