

Glass and Glazing Federation

Certifies that

Garware Polyester Ltd


Certificate No: *TC 0150*

Garware 200 Micron Combination Solar Safety Film on 6mm Float Glass passed Class A of ANSI Z97.1 American National Standard for Safety Glazing Materials used in Building-Safety Performance Specification and Methods of Test

Tested at Wintech Engineering Ltd, UKAS accredited Test Laboratory, No.2223


Issued: *16/12/2002*

Chief Executive:



N Rees

Testing Officer:



S H Rice



Glass and Glazing Federation

Glass and Glazing Federation
44 - 48 Borough High Street
London
SE1 1XB
Tel: 020 7207 5872
Fax: 020 7357 7458

Test Facility:
WINTech Engineering Ltd
Halesfield 2
Telford TF7 4QH
Tel: 01952 586580
Fax: 01952 586585