

Glass and Glazing Federation

Certifies that

Garware Polyester Ltd


Certificate No: **TC 0200**

Garware 200 Micron Combination Solar Safety Film on 6.8mm
Laminated Glass
Passed Class P2A (Drop height 3 metre)
of BS EN 356:2000 'Glass in Building – Security Glazing-Testing
and Classification of resistance against manual attack'

Tested at Wintech Engineering Ltd, UKAS accredited Test Laboratory, No.2223

Issued: **29/03/2004**

Chief Executive:



N Rees

Testing Officer:



S H Rice

Test Facility:
WİNTECH Engineering Ltd
Halesfield 2
Telford TF7 4QH
Tel: 01952 586580
Fax: 01952 586585



Glass and Glazing Federation

Glass and Glazing Federation
44 – 48 Borough High Street
London
SE1 1XB
Tel: 020 7207 5872
Fax: 020 7357 7458